



PAVEMENT SCHEDULE

- ① 1.5" - BITUMINOUS SURFACE COURSE
411-02.10 ACS MIX (PG 70-22) GRADING D RDWY
- ② TACK COAT
403-01 BITUMINOUS MATERIAL FOR TACK COAT (TC) @0.07 GAL/SY (@0.10 GAL/SY MILLED SURFACES)
- ③ 3" - BITUMINOUS AGGREGATE BASE
307-02.08 ASPHALT CONCRETE MIX (PG 70-22) (BPMB-HM) GRADING B-M2
- ④ 4" - BITUMINOUS AGGREGATE BASE (460 LB/SY)
307-02.01 ASPHALT CONCRETE MIX (PG 70-22) (BPMB-HM) GRADING A
- ⑤ PRIME COAT
402-01 BITUMINOUS MATERIAL FOR PRIME COAT (PC) @0.30-0.35 GAL/SY
402-02 AGGREGATE FOR COVER MATERIAL (PC) @8-12 LB/SY
- ⑥ 10" - MINERAL AGGREGATE BASE
303-01 MINERAL AGGREGATE, TYPE A BASE, GRADING D

NOTES

- 1. THICKNESSES SHOWN ARE MINIMUMS. FINAL DESIGN THICKNESS TO BE DETERMINED BY A GEOTECHNICAL ENGINEER.
- 2. REFERENCE "STANDARD SPECIFICATIONS FOR ROAD AND BRIDGE CONSTRUCTION" OF THE TENNESSEE DEPARTMENT OF TRANSPORTATION



HISTORIC
FRANKLIN
TENNESSEE

MAJOR AND MINOR COLLECTOR PAVEMENT SECTION

CITY OF FRANKLIN

NOT TO SCALE

CITY
ENGINEER:

Paul P. Hoyle

DATE:

7/1/2021

DWG. NO.

RD-2