



NOTES

1. DETAIL TO BE USED WITH MILBANK SERVICE PEDESTAL MODEL NUMBER CP3B71110A22SL1 OR APPROVED EQUAL.
2. FINISH SHALL BE POWDER COATED TO MATCH SHERWIN-WILLIAMS #PGS4-1059-FC (FRANKLIN GREEN) WHEN LOCATED IN HISTORIC DOWNTOWN FRANKLIN AREA.
3. AT THE DIRECTION OF THE OF ENGINEERING DEPARTMENT, THE PEDESTAL FOUNDATION MAY BE POURED INTEGRALLY WITH THE TRAFFIC SIGNAL CABINET FOUNDATION. LOCATION DEPENDENT ON CABINET PHOTOCELL PLACEMENT. PHOTOCELL TO BE POSITIONED FACING SOUTH TO SOUTHEAST.
4. CONCRETE: CLASS A (3,000 PSI, 6% AIR)
5. GROUNDING: PER UTILITY PROVIDER SPECIFICATIONS
6. CONDUIT:
  - A. PROVIDE 1" RGS CONDUIT FOR POWER TO TRAFFIC SIGNAL CABINET.
  - B. PROVIDE CONDUIT PER UTILITY PROVIDER SPECIFICATIONS FOR GROUNDING AND TO POWER SOURCE.
  - C. ALL CONDUIT SHALL USE LONG SWEEP RADII (MINIMUM 6" RADIUS).



HISTORIC  
FRANKLIN  
TENNESSEE

**ELECTRICAL SERVICE DETAILS FOR TRAFFIC SIGNAL**

CITY OF FRANKLIN

NOT TO SCALE

CITY  
ENGINEER:

*Paul P. Hoyle*

DATE:

7/1/2022

DWG. NO.

**ITS-5**