



MEMORANDUM

June 8, 2010

TO: Board of Mayor and Aldermen

FROM: Eric Stuckey, City Administrator
Russ Truell, Assistant City Administrator/CFO
Fred Banner, IT Director

SUBJECT: Replacement Batteries for MIT back-up power and power conditioning system

Purpose

The purpose of this memorandum is to present information to the Board of Mayor and Alderman (BOMA) to consider the purchase of 12 replacement batteries in the APC power conditioning unit in the MIT server room.

Background

As a part of our information technology (IT) infrastructure, the City has an APC unit that provides continuous power to computer servers before the main generator for City Hall activates during a power outage. If the main generator fails or stops due to lack of fuel, this unit provides for the orderly shut-down of computer hardware. The batteries in our APC power conditioning unit are 6 years old and need to be replaced. The unit is displaying that the life of the batteries are expiring.

Financial Impact

The purchase price from Pomeroy is \$14,483.88 (12 x \$1,206.99). These batteries are available on the Tennessee State contract #4037020. The commodity code is #20545. The MIT budget line item is 83500.

Recommendation


Purchase of these replacement batteries from Pomeroy through Tennessee State Contract #4037020 is recommended.

Date: 6/2/2010

Quoted By: Marilyn Yunker

Phone Extension: 615-399-0404 x5208

E-mail Address: myunker@pomeroys.com



City of Franklin					
APC Replacement Batteries					
Product	Description	Price	Qty	Extended	
WMBRS4-MB-T4	Modular Battery Replacement Service 4 x SYBT4 - See attached SOW for services	\$ 6,418.00	3	\$ 19,254.00	
	Estimated Freight Charges				
SYBT4	Battery Module for Symmetra PX or Smart-UPS VT (224 lbs) - BATTERY ONLY	\$ 1,206.99	12	\$ 14,483.88	