



NOTES

1. SIDEWALK CROSS SLOPE: 1.5% DESIRABLE, 2.0% MAX.
2. APRON RAMP SLOPE: 8% MAX., 1.5% MIN.
3. MINERAL AGGREGATE BASE: 4" MIN. THICK 303-01 MINERAL AGGREGATE, TYPE A BASE, GRADING D
4. CONCRETE: 8" MIN. THICK CLASS A (3,000 PSI, 6% AIR) WITH SYNTHETIC FIBER REINFORCEMENT
5. EXPANSION JOINTS: 1/2" THICK U.N.O. (SEE ALSO DRAWING RP-10)
  - A. RUBBERIZED EXPANSION JOINT FILLER (AASHTO M153, TYPE 1)
6. DETECTABLE WARNING: YELLOW (EXCEPT PER SECTION 2.4.8), CAST-IN-PLACE (ADA SOLUTIONS OR APPROVED EQUAL)
7. APRON RADIUS:
  - A. 15'-0" MIN. AT ALLEYS
  - B. 25'-0" MIN. AT MEWS



<b>ALLEY / MEWS APPROACH APRON</b>		DWG. NO.
CITY OF FRANKLIN	CITY ENGINEER: <i>Paul P. Hoyle</i>	<b>SD-5</b>
NOT TO SCALE		DATE: 7/1/2023